



NOTE: EMS CONTROL PANELS SHALL BE MOUNTED ON SIDE OF EACH AH AND (1) MOUNTED NEAR HX-1 IN PENTHOUSE. PROVIDE ROUTER AND INTEGRATE WITH (E) EMS SYSTEM. DUCT SMOKE DETECTORS SHALL BE PROVIDED AND INSTALLED IN DUCT BY MECHANICAL AND WIRED BY ELECTRICAL.

[illegible]

**LP**  
**LP Consulting**  
**Engineers, Inc.**  
885 W. Ashton Ave., Suite 101 Clark, CA 95611  
p 956-346-2130 - f 956-346-2131  
www.lppacific.com  
Job #: 10-71096



**HMC** Architects  
1827 E. Ft. Avenue, Studio 103 / Fresno, CA 93720  
T 559 322 2444 / [www.hmcarchitects.com](http://www.hmcarchitects.com)

**Drawing Title**  
**ENERGY MANAGEMENT**  
**SYSTEM (EMS)**

**Project Title**  
**BUILDING 24**  
**SEISMIC CORRECTION**  
**AND ADDITION**

Project Number	570-215
Building Number	24

Office of  
Construction  
and Facilities  
Management